

SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658

Jim Doyle, Governor Mary P. Burke, Secretary

February 17, 2004

ADVANCED DRAINAGE SYSTEMS, INC.

SALES

BRENT A.YEAGER

1814 PINEVIEW DR.

VERONA WI 53593

NYLOPLAST

ADS INC

BRENT A. YEAGER

1814 PINEVIEW DR

VERONA WI 53593

Re: Description: STORMWATER DRAINAGE, ALTERNATE PLUMBING SYSTEM

Manufacturer: NYLOPLAST

Product Name: NYLOPLAST PVC STORM DRAINAGE SYSTEM

Model Number(s): Drain Basins, Road and Highway structure type inlets basins and Drain Basin/Curb Inlet

Drain structure type inlets in 8", 10", 12", 15", 18", 24" and 30" diameters.

Product File No: 20030271

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 82.35 based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of February 2009.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This product must be installed in accordance with the manufacturer's printed instructions, system approval, plan approval, and Wis. Adm. Code. If there is a conflict between the manufacturer's instructions and the plan approval, system approval or Wis. Adm. Code, the Wis. Adm. Code, plan approval and system approval will take precedence.
- Location of flow through openings of Drain Basins, Road and Highway structure type inlets basins and Drain Basin / Curb Inlet Drain structure type inlets basins may be at variable elevations and/or locations around the axis of the basin in accordance with manufacturer's specifications noted on drawings numbered 7001-110-012, 7001-110-013, 7001-110-014 entitled 8" and 15" Minimum Angle Between Adapters, 18" and 24" Minimum Angle Between Adapters and 30" Minimum Angle Between Adapters, respectively.
- All connections to storm sewer piping shall be made with the use of watertight adapters.
- All storm sewer materials shall comply with applicable standards referenced in Comm 84 of the Wisconsin Administrative Code.
- When this system is installed without clean outs as required by s. Comm 82.35, Wisconsin Administrative Code, the system must be cleaned by the use of vacuum or jetting system.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

SBD-10564-E (N.10/97) File Ref: 03027101.DOC

ADVANCED DRAINAGE SYSTEMS, INC. Page 2 February 17, 2004

Sincerely,

Michael J. Beckwith, CIPE Plumbing Product Reviewer phone: 608-266-6742

fax: 608-267-9566

e-mail: mike.beckwith@wisconsin.gov